



# Beverly Hills Police & Fire

18600 West Thirteen Mile Road  
Beverly Hills, MI 48025  
248-540-3400

Inspection: Commercial Fire Safety Checklist

Status: N/A

Inspector: Self Inspection

Date:

Occupancy  
Name:

CFS #: N/A

Address:

City: Beverly Hills

Contact:

Phone:

## Address

- Address clearly visible from the street
- Address on back door visible (4" minimum)

## Fire Department Access

- Fire access road free of permanent impediments
- Knox Box present
- Knox Box has proper key

## Fire Resistance of Structure

- Building exterior not compromised
- Ceiling tiles not damaged or missing
- No openings in fire wall

## Means of Egress

- Doors free from chains and bolt locks
- General housekeeping is neat & orderly
- All exits are free from obstructions
- All panic hardware operates properly

## Emergency Lights

- Emergency lights present when required
- Emergency lights illuminate when required

## Exit Signs

- Exit signs over all exit doors
- Exit signs illuminate when required

## Fire Extinguishers

- Fire extinguishers mounted properly
- Fire extinguishers are accessible
- Fire extinguishers are serviced annually

## Electrical

- All electrical boxes/hazards covered or abated
- Electrical service panels have 36" clearance
- Extension cords not overloaded
- Extension cords not used as permanent wiring
- Meter free of damage
- Meter free of corrosion

## Natural Gas

- Meter free of damage
- Meter free of corrosion

## Fire Prevention

- 2' clearance from stock to ceiling
- Combustible liquids clear of ignition sources
- Combustible materials clear of ignition sources
- Area under stairways not used for storage
- Fueled equipment stored properly

## Fire Department Connection

- Yes  No FDC present
- FDC Properly Marked
- FDC access free of impediments
- FDC caps in place
- FDC cap spins freely
- FDC pipe clear of blockage

## Compressed Gas Cylinders

- Yes  No Compressed Gas Cylinders present
- Compressed Gas Cylinders properly marked
- Compressed Gas Cylinders chained at all times

## LP Gas Tanks

- Yes  No LP Gas tanks present
- LP Gas tanks properly marked
- LP Gas tanks properly stored

## Hazardous Materials

- Yes  No Hazardous Materials present
- Hazardous Materials properly marked
- Hazardous Materials properly stored

## Fire Alarm

Yes  No Fire Alarm present

Company:

Alarm tested

## Fire Protection/Sprinkler System

Yes  No Sprinklers present

Valves in open position

Valves monitored

System tested

Spare heads (<300=6 / 300-1000=12 / >1000=24)

## Smoke Detectors

Yes  No Smoke Detectors present

Smoke Detectors operating properly

## Commercial Kitchen System

Yes  No Hood Suppression System

Hood Suppression System UL 300 compliant

System tested

Yes  No Hood Vent System

Hood Vent System clean and free of grease

System tested

Ⓟ [ c•• ]: